

**Edenville Township
2011 Water Main Improvements
Water District No. 1 of Midland County**

A water main is being constructed along your road.


Please complete and return this form by May 18, indicating the desired service lead location in your yard with a stake, flag, or other clearly indicated marker. If needed, a flag can be obtained for marking from the Township Hall. **If no preference is indicated, the service lead will be placed using our best judgement .**

Do Not run a water line from your home to the water main at this time. You will receive a letter at a later date from the Township office explaining the procedure to obtain a permit to run your water line. Please do not contact Water District No. 1 or the Code Authority with questions at this time. If you have questions, please contact the Township office at 989-689-3655.


On the diagram below please indicate your preference as to the location of the water main service lead, at your property line. It will be helpful to provide dimensions from physical features on your property to show the location of your service lead.

- Allow 10 feet of separation from any sewage disposal facility.
- Allow a minimum 5 feet of clearance on either side of the line for future repairs.
- Meter must be in a heated accessible area - no installation in crawl spaces.
- Keep at least 5 feet off of driveways.
- This service lead must be within the property/address to be served, or centered within a 10 foot water easement deeded to the property/address to be served.

℞



℞



CIRCLE ONE

RIGHT-OF-WAY

ROAD NAME

NAME: _____

DATE: _____

ADDRESS: _____

PARCEL ID NUMBER

RETURN ADDRESS:
Civil Engineering Consultants
P.O. Box 130
Auburn, MI 48611
Phone: (989) 662-2040